


DRAWING REF	LIBRARY REF	DESCRIPTION
1	K3	Cabinet 390x290x160mm
2		Mounting Bracket for Cabinet
3	K16	Digichem - XP2 Controller
4	K10	PG9 Cable Gland - Spare
5	K10	PG9 Cable Gland - Probe
6	K6	20mm Cable Gland - Mains Power and Solenoid
7	K6	20mm Cable Gland - Pumps A,B and C
8	K49	Pump C Inhibitor. Seko 1.3L/h
9	K49	Pump A Biocide. Seko 1.3L/h
10	K49	Pump B Biocide. Seko 1.3L/h
11	K5	16mm Cable Gland - Solenoid
12	K5	16mm Cable Gland - Probe
13	K5	16mm Cable Gland - Mains Power
14	K5	16mm Cable Gland - Spare
15		Mounting Plate 350x250mm - 4.5mm Thick
16	M67	Hosetail 12mm x 3/4"
17	M112	Inlet Female Socket 20 x 3/4"
18	M82	Pipe Clip 1"
19	M104	Clear20mm Pipe - 96mm
20	M72	Hosetail 6mm x 1/2" Elbow
21	M74	Mini Ball Valve 1/2"
22	M129	Tee 20mm x 1/2"
23	M52	Elbow 20mm
24	M130	Tee 20mm x 3/4"
25	M87	Conductivity Probe 3/4"
26	M128	Tee 20mm
27	M12	Barrell Union 20mm
28	M5	Adaptor Male 20mm x 1/2"
29	M119	Bleed Solenoid - SMC 1/2"
30	M115	Socket Male 20mm x 1/2"
31	M92	Clear 20mm Pipe cut to 67mm
32	M112	Bleed Outlet - Socket Female 20mm x 3/4
33	M2	Adaptor Female 20mm x 3/4"
34	M37 / M6	Check Valve inserted inside Adaptor Male 20mm x 3/4"
35	M129	Injection Valve for Inhibitor
36	M129	Injection Valve for Biocide A
37	M129	Injection Valve for Biocide B
38	M6	Male Adaptor 20mm x 3/4"
39	M2	Manifold Outlet - Adaptor Female 20mm x 3/4"
40		PVC Board 345 x 300mm - 10mm Thick



**Convergent Water Controls**

THIS DRAWING IS COPYRIGHT AND THE PROPERTY OF CONVERGENT WATER CONTROLS PTY LTD ABN 58 082 819 734. IT IS SUBJECT TO THEIR RECALL AND MAY NOT BE REPRODUCED OR ITS CONTENTS DIVULGED WITHOUT WRITTEN AUTHORITY.

Ver	1.0	Date	07/02/08	Notes	ORIGINAL	By	LF	Check	LN
-----	-----	------	----------	-------	----------	----	----	-------	----

Filename  
\\FILENAME

Drawn By  
LF

Checked By  
LN

Scale  
N/A

Dimensions  
DIMENSIONS ARE IN MM  
DO NOT SCALE

Date  
07/02/08

Title  
ASSEMBLY DRAWING

Project / Part Number  
DIGICHEM-AB2-V-CABG

Client  
CONVERGENT WATER CONTROLS

Ver  
1.0

Drawing No  
DRAWING NO