

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Acetaldehyde	75-07-0	<40%	OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	OK	OK	OK	OK
		>40%	OK(T)	LIM	LIM	NO	NO	NO	OK	NO	OK	
Acetamide	60-35-5	<50%	OK	OK	OK	---	---	OK	OK	OK	OK	
		>50%	OK	OK	OK	NO	NO	OK	OK	OK	OK	
Acetic acid	64-19-7	10%	NO	NO	OK	LIM	OK	NO	OK	NO	OK	
		20%	NO	NO	OK	NO	OK	NO	OK	NO	OK	
		20..50%	NO	NO	OK	NO	OK	NO	LIM	NO	OK	
		>50%	NO	NO	OK	NO	OK	NO	NO	NO	NO	
Acetone	67-64-1	<50%	NO	NO	OK(T)	LIM	OK(T)	NO	OK	NO	OK	
		>50%	NO	NO	NO	NO	NO	NO	OK	NO	OK	
Adipic acid	124-04-9		---	---	OK	---	OK	OK	OK	OK	OK	
Ammonia	7664-41-7	<20%	OK	OK	OK	OK	OK	NO	OK	NO	OK	
		>20%	OK	OK	OK	OK	OK	NO	OK	NO	OK	
Ammonium chloride	12125-02-9	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Ammonium fluoride	12125-01-8	<14%	---	---	LIM	---	OK	OK	OK	OK	OK	
		>14%	---	---	NO	NO	OK	OK	OK	OK	OK	
Ammonium hydroxide	1336-21-6	<28%	OK	OK	OK	OK	OK	LIM	OK	OK	OK	
		>28%	---	---	LIM	LIM	LIM	LIM	OK	OK	OK	
Ammonium nitrate	6484-52-2		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Ammonium sulfate	7783-20-2	<50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>50%	LIM	LIM	LIM	LIM	OK	OK	OK	OK	OK	
Ammonium sulfide	12135-76-1	<20%	---	---	OK	---	OK	OK	OK	OK	OK	
		>20%	---	---	OK	---	OK	OK	OK	OK	OK	
Aniline	62-53-3		NO	NO	NO	NO	NO	LIM	NO	OK	NO	
Aqua regia	8007-56-5	<10%	NO	NO	NO	NO	NO	NO	NO	NO	NO	
		>10%	NO	NO	NO	NO	NO	NO	NO	NO	NO	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Arsenic acid	7778-39-4	<10%	---	---	OK	---	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	OK	LIM	OK	OK	OK	OK	OK	OK
Barium chloride	10361-37-2	<10%	NO	NO	NO	NO	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	NO	NO	OK	OK	OK	OK	OK	OK
Barium hydroxide	17194-00-2	<10%	---	---	OK	---	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	OK	---	OK	OK	OK	OK	OK	OK
Benzaldehyde	100-52-7	<10%	OK	OK	OK	OK	OK	NO	OK	NO	OK	OK
		>10%	OK(T)	NO	NO	NO	NO	NO	NO	NO	NO	NO
Benzene	71-43-2		LIM	NO	NO	NO	NO	OK	NO	OK	NO	NO
Benzoic acid	65-85-0	<10%	---	---	OK	---	OK	OK	NO	OK	NO	NO
		>10%	NO	NO	OK	NO	OK	OK	NO	OK	NO	NO
Benzyl alcohol	100-51-6		NO	NO	LIM	LIM	LIM	OK	LIM	OK	OK	OK
Boric acid	10043-35-3		NO	NO	OK	LIM	OK	OK	OK	OK	OK	OK
Butyl cellosolve (Butilglicole)	111-76-2		---	---	---	---	---	NO	OK	NO	OK	OK
Butyric acid	107-92-6	<20%	NO	NO	LIM	LIM	LIM	LIM	OK	OK	OK	OK
		>20%	NO	NO	NO	NO	NO	LIM	LIM	OK	OK	OK
Calcium bisulfite	13780-03-5	<10%	---	---	OK	---	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	OK	---	OK	OK	NO	OK	NO	NO
Calcium carbonate	471-34-1		OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Calcium chloride	10043-52-4	<10%	NO	NO	OK	---	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	LIM	LIM	OK	OK	OK	OK	OK	OK
Calcium hydroxide	1305-62-0	<15%	NO	NO	OK	NO	OK	OK	OK	OK	OK	OK
		>15%	NO	NO	OK	NO	NO	OK	OK	OK	OK	OK
Calcium hypochlorite	7778-54-3	<10%	---	---	LIM	---	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	LIM	LIM	OK	OK	OK	OK	OK	OK
Calcium nitrate	10124-37-5	<50%	---	---	OK	---	OK	OK	OK	OK	OK	OK
		>50%	---	---	OK	---	OK	OK	OK	OK	OK	OK

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Calcium sulfate	7778-18-9		---	---	OK	---	OK	OK	OK	OK	OK	
Chloric acid	7790-93-4	<10%	---	NO	LIM	---	OK	OK	OK	OK	OK	
		>10%	---	NO	NO	NO	NO	OK	OK	OK	OK	
Chlorine dioxide	10049-04-4		---	NO	NO	LIM	LIM	OK	NO	OK	NO	
Chloroacetic acid	79-11-8	<50%	NO	NO	NO	---	OK	NO	LIM	NO	OK	
		>50%	NO	NO	NO	NO	NO	NO	LIM	NO	OK	
Chlorosulfonic acid	7790-94-5	<10%	NO	NO	---	---	---	---	---	---	---	
		>10%	NO	NO	NO	NO	NO	NO	NO	NO	NO	
Chromic acid	7738-94-5	<30%	NO	NO	NO	NO	NO	OK	NO	OK	NO	
		>30%	NO	NO	NO	NO	NO	LIM	NO	OK	NO	
Citric acid	77-92-9	<10%	LIM	LIM	OK	LIM	OK	OK	OK	OK	OK	
		>10%	LIM	LIM	OK	LIM	OK	OK	OK	OK	OK	
Copper nitrate	10031-43-3	<25%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>25%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Copper sulfate	7758-98-7	<5%	NO	NO	OK	---	OK	OK	OK	OK	OK	
		>5%	NO	NO	OK	---	OK	OK	OK	OK	OK	
Cresol	95-48-7	<50%	---	---	OK	---	OK	OK	NO	OK	NO	
		>50%	NO	NO	NO	NO	NO	LIM	NO	OK	NO	
Cyclohexane	110-82-7		OK(T)	NO	NO	NO	NO	OK	NO	OK	NO	
Diesel fuel	68334-30-5		OK	OK	OK	OK	OK	OK	NO	OK	NO	
Diethanolamine	111-42-2		OK(T)	NO	NO	NO	NO	LIM	OK	OK	OK	
Diethyl ether	60-29-7		NO	NO	NO	NO	NO	NO	NO	NO	NO	
Diethylamine	109-89-7	<10%	---	---	OK	NO	NO	NO	OK	NO	OK	
		>10%	LIM	LIM	OK(T)	NO	NO	NO	LIM	NO	OK	
Diethylene glycol	111-46-6		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Diethylene triamine	111-40-0		---	NO	NO	NO	NO	---	---	---	---	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS					
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX			
Diglycolic acid	110-99-6	<30% 30%	---	NO	OK	LIM	OK	LIM	OK	OK	OK	OK	OK	OK
Dimethylformamide	68-12-2		NO	NO	OK(T)	NO	NO	NO	NO	NO	NO	NO	NO	NO
Dioxane	123-91-1		OK(T)	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
Ethane	74-84-0		OK	NO	NO	NO	NO	NO	NO	OK	NO	OK	NO	NO
Ethanol	64-17-5	<40% >40%	OK NO	OK NO	OK OK(T)	OK LIM	OK OK(T)	OK OK(T)	OK OK	OK OK	OK OK	OK OK	OK OK	OK OK
Ethanolamine	141-43-5		NO	NO	NO	NO	NO	NO	NO	NO	OK	NO	OK	OK
Ether	60-29-7		OK(T)	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
Ethyl acetate	141-78-6		LIM	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
Ethyl chloride	75-00-3		OK(T)	NO	NO	NO	NO	NO	LIM	OK	OK	OK	OK	OK
Ethylene diamine	107-15-3		LIM	LIM	OK(T)	NO	NO	NO	NO	OK	NO	OK	OK	OK
Ethylene glycol	107-21-1		OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Ethylene oxide	75-21-8		LIM	LIM	LIM	LIM	OK(T)	LIM	OK(T)	NO	NO	NO	NO	NO
Fatty acids	68937-75-7		OK	OK	OK	OK	OK	OK	OK	NO	OK	OK	NO	NO
Formaldehyde	50-00-0	<40% >40%	OK OK(T)	OK OK(T)	OK OK(T)	OK OK(T)	OK OK(T)	OK OK(T)	OK OK	OK OK	OK OK	OK OK	OK OK	OK OK
Formamide	75-12-7		OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	LIM	OK	OK	OK	OK	OK
Formic acid	64-18-6	<50% >50%	NO ---	NO NO	OK NO	NO NO	OK NO	NO NO	NO NO	OK OK	NO OK	NO NO	OK OK	OK OK
Fructose	57-48-7		---	---	OK	---	OK	---	OK	OK	OK	OK	OK	OK
Fruit juice	N/A		NO	NO	OK	---	OK	---	OK	OK	OK	OK	OK	OK
Fuel oil	N/A		OK	OK	OK	OK	OK	OK	OK	NO	OK	NO	OK	NO
Gasoline			OK	NO	NO	NO	NO	NO	NO	NO	OK	NO	OK	NO

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Glacial acetic acid	64-19-7	<50%	---	---	OK	---	OK	NO	LIM	NO	OK	
		>50%	---	---	LIM	LIM	LIM	LIM	NO	LIM	NO	OK
Glucose	50-99-7		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Glycerine	56-81-5		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Glycerol	56-81-5		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Glycolic acid	79-14-1	<37%	NO	NO	OK	---	OK	OK	OK	OK	OK	
		>37%	NO	NO	OK	---	OK	OK	OK	OK	OK	
Hydraulic oil	64742-54-7		OK	NO	NO	NO	NO	OK	NO	OK	NO	
Hydrobromic acid	10035-10-6	<48%	NO	NO	NO	NO	NO	OK	OK	OK	OK	
		>48%	NO	NO	NO	NO	NO	OK	OK	OK	OK	
Hydrochloric acid	7647-01-0	<37%	NO	NO	NO	LIM	OK	OK	OK	OK	OK	
		>37%	NO	NO	NO	LIM	OK	OK	LIM	OK	OK	
Hydrocyanic acid	3017-23-0	<10%	---	NO	NO	---	OK	OK	OK	OK	OK	
		>10%	NO	NO	NO	LIM	LIM	LIM	LIM	OK	OK	
Hydrofluoric acid	7664-39-3	<50%	LIM	LIM	LIM	LIM	OK	OK	LIM	OK	OK	
		>50%	NO	NO	NO	NO	NO	OK	LIM	OK	OK	
Hydrofluosilicic acid	16961-83-4	<32%	NO	NO	NO	---	OK	OK	OK	OK	OK	
		>32%	NO	NO	NO	---	OK	OK	OK	OK	OK	
Hydrogen sulfide	7783-06-4	<10%	LIM	LIM	LIM	LIM	OK	---	---	---	---	
		>10%	LIM	LIM	LIM	LIM	OK	NO	LIM	NO	OK	
Hypochlorous acid	7790-92-3		---	NO	NO	---	OK	OK	OK	OK	OK	
Iodine	7553-56-2	<10%	---	NO	NO	NO	OK(T)	OK	OK	OK	OK	
		>10%	NO	NO	NO	NO	NO	OK	OK	OK	OK	
Isobutanol	78-83-1		OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	OK	OK	OK	OK	
Isopropyl alcohol	67-63-0		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Isopropyl ether	108-20-3		NO	NO	NO	NO	NO	NO	NO	NO	NO	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS				
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX		
Kerosene	64742-48-9		OK	OK	OK	OK	OK	OK	OK	OK	NO	OK	NO
Lactic acid	50-21-5	<50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>50%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	OK	OK
Lead acetate	301-04-2	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	LIM	LIM	LIM	OK	OK	NO	OK	NO	OK	OK	OK
Linseed oil	8001-26-1		OK	OK	OK	OK	OK	OK	OK	NO	OK	NO	
Magnesium chloride	7786-30-3	<10%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	NO	LIM	OK	OK	OK	OK	OK	OK	OK
Magnesium oxide	1309-48-4		OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Magnesium sulfate	7487-88-9	<10%	---	---	OK	---	OK	OK	OK	OK	OK	OK	OK
		>10%	---	---	OK	---	OK	OK	OK	OK	OK	OK	OK
Maleic acid	110-16-7	<25%	NO	NO	OK	---	OK	OK	---	OK	OK	OK	OK
		>25%	NO	NO	OK	---	OK	OK	LIM	OK	OK	OK	OK
Mercuric chloride	7487-94-7		NO	NO	NO	NO	OK	OK	OK	OK	OK	OK	
Methane	74-82-8		OK	OK	OK	OK	OK	OK	OK	NO	OK	NO	
Methanol	67-56-1	<15%	OK	OK	OK	OK	OK	---	OK	---	OK	OK	
		>15%	NO	NO	OK(T)	LIM	OK(T)	NO	OK	NO	OK	OK	
Methyl acetate	79-20-9		LIM	NO	NO	NO	NO	NO	NO	NO	NO	NO	
Methyl alcohol	67-56-1	<50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>50%	OK	OK	OK	OK	OK	LIM	OK	OK	OK	OK	
Methyl bromide	155-41-9		NO	NO	NO	NO	NO	OK	NO	OK	NO		
Methyl chloride	74-87-3		OK(T)	NO	NO	NO	NO	NO	NO	NO	NO		
Methyl ethyl ketone	78-93-3	<20%	---	---	---	---	---	---	OK	---	OK		
		>20%	NO	NO	NO	NO	NO	NO	OK	NO	OK		
Milk	8049-98-7		OK	OK	OK	OK	OK	OK	OK	OK	OK		

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS				
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX		
Monopotassium phosphate	7778-77-0		---	---	---	---	OK	---	---	---	---	---	---
Muriatic acid	7647-01-0	<30%	---	NO	NO	---	OK	OK	OK	OK	OK	OK	OK
		>30%	---	NO	NO	---	---	OK	LIM	OK	OK	OK	
Naphthalene	91-20-3		OK(T)	LIM	LIM	LIM	LIM	OK	NO	OK	NO	NO	
Nickel sulfate	10101-97-0	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	OK	OK
Nitric acid	7697-37-2	<50%	NO	NO	OK	LIM	OK	OK	LIM	OK	OK	OK	OK
		>50%	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
Nitrobenzene	98-95-3		LIM	LIM	LIM	LIM	LIM	NO	NO	NO	NO	NO	
Olaic acid	112-80-1		OK	LIM	LIM	LIM	LIM	LIM	NO	OK	NO	NO	
Ozone	10028-15-6	<2%	---	NO	NO	NO	NO	OK	OK	OK	OK	OK	OK
		>2%	NO	NO	NO	NO	NO	OK	OK	OK	OK	OK	
Peracetic acid	79-21-0	<40	NO	NO	NO	NO	NO	OK	OK	OK	OK	OK	OK
		>40	NO	NO	NO	NO	NO	OK	OK	OK	OK	OK	
Perchloric acid	7601-90-3	<10%	---	NO	LIM	LIM	OK	OK	OK	LIM	OK	OK	OK
		>10%	---	NO	NO	LIM	LIM	OK	LIM	OK	OK	OK	
Phenol	108-95-2	<50%	LIM	LIM	OK(T)	LIM	OK(T)	OK	LIM	OK	OK	OK	OK
		>50%	NO	NO	NO	NO	NO	LIM	NO	OK	NO	NO	
Phosphoric acid	7664-38-2	<50%	NO	NO	LIM	NO	OK	OK	OK	OK	OK	OK	OK
		>50%	NO	NO	NO	NO	NO	OK	OK	OK	OK	OK	
Phosphorus trichloride	7719-12-2		NO	NO	NO	NO	NO	LIM	LIM	OK	OK	OK	
Phthalic acid	88-99-3	<50%	---	---	OK	---	OK	---	OK	OK	OK	OK	OK
		>50%	OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	LIM	OK	OK	OK	OK	
Pine oil	7732-18-5		---	---	OK	---	OK	OK	NO	OK	NO	NO	
Potassium bromide	7758-02-3	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Potassium carbonate	584-08-7	<50%	OK	OK	OK	NO	NO	LIM	OK	OK	OK	
		>50%	OK	OK	OK	NO	NO	LIM	OK	OK	OK	
Potassium chloride	7447-40-7	<10%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	
		>10%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	
Potassium cyanide	151-50-8	<50%	---	---	OK	LIM	OK	LIM	OK	OK	OK	
		>50%	LIM	LIM	LIM	LIM	OK	LIM	OK	OK	OK	
Potassium hydroxide	1310-58-3	<30%	OK	OK	OK	OK	OK	NO	OK	NO	OK	
		>30%	LIM	LIM	OK	LIM	OK	NO	OK	NO	OK	
Potassium hypochlorite	7778-66-7	<15%	---	NO	NO	NO	NO	OK	OK	OK	OK	
		>15%	---	NO	NO	NO	NO	OK	OK	OK	OK	
Potassium iodide	7681-11-0	<50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Potassium nitrate	7757-79-1	<24%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>24%	---	---	OK	---	OK	OK	OK	OK	OK	
Potassium permanganate	7722-64-7	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Potassium phosphate tribasic	7778-53-2		---	---	OK	---	---	---	OK	---	OK	
Potassium sulfate	7778-80-5		OK	OK	OK	OK	OK	OK	OK	OK	OK	
Potassium thiosulfate	10294-66-3		---	---	---	---	---	OK	---	OK	---	
Propionic acid	79-09-4	<50%	NO	NO	OK	---	OK	OK	OK	OK	OK	
		>50%	---	NO	LIM	LIM	LIM	OK	OK	OK	OK	
Propylene glycol	57-55-6		LIM	LIM	LIM	OK(T)	OK(T)	OK	OK	OK	OK	
Propylene oxide	75-56-9		---	LIM	LIM	NO	NO	NO	NO	NO	NO	
Pyridine	110-86-1	<5%	---	LIM	LIM	---	---	---	---	---	---	
		>5%	NO	NO	NO	NO	NO	NO	NO	NO	NO	
Quaternary ammonium	68424-85-1	<10%	OK	OK	OK	OK	OK	---	---	---	---	
Silicone			---	---	OK	---	OK	OK	OK	OK	OK	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Silicone oil	63148-62-9		---	---	OK	---	OK	OK	LIM	OK	OK	
Silver nitrate	7761-88-8	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Soda ash	497-19-8		---	---	OK	---	OK	OK	OK	OK	OK	
Sodium acetate	127-09-3	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	LIM	LIM	LIM	OK	OK	NO	OK	NO	OK	
Sodium benzoate	532-32-1	<10%	---	---	OK	---	OK	OK	OK	OK	OK	
		>10%	---	---	OK	---	OK	OK	OK	OK	OK	
Sodium bicarbonate	144-55-8	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Sodium bisulfate	7681-38-1	<10%	LIM	LIM	OK	LIM	OK	OK	OK	OK	OK	
		>10%	---	---	OK	---	OK	OK	OK	OK	OK	
Sodium bromide	7647-15-6	<50%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>50%	NO	NO	NO	NO	OK	OK	OK	OK	OK	
Sodium carbonate	497-19-8	<10%	OK	OK	OK	NO	NO	OK	OK	OK	OK	
		>10%	OK(T)	OK(T)	OK(T)	OK(T)	OK(T)	OK	OK	OK	OK	
Sodium chloride	7647-14-5	<10%	NO	NO	NO	NO	---	OK	OK	OK	OK	
		>10%	NO	NO	NO	NO	---	OK	OK	OK	OK	
Sodium chlorite	7758-19-2	<10%	---	---	---	---	OK	OK	OK	OK	OK	
		>10%	---	NO	OK(T)	NO	OK(T)	NO	NO	NO	NO	
Sodium cyanide	143-33-9		LIM	LIM	LIM	OK	OK	OK	OK	OK		
Sodium fluoride	7681-49-4	<4%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>4%	NO	NO	NO	NO	---	OK	OK	OK	OK	
Sodium hydroxide	1310-73-2	<50%	LIM	LIM	LIM	NO	NO	NO	OK	NO	OK	
		>50%	---	LIM	LIM	NO	NO	NO	NO	NO	NO	
Sodium hypochlorite	7681-52-9	<20%	NO	NO	NO	NO	NO	OK	NO	OK	NO	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS			
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX	
Sodium hypochlorite	7682-52-9	>20%	NO	NO	NO	NO	NO	LIM	NO	OK	NO	
Sodium metasilicate	6834-92-0		---	---	OK	---	OK	OK	OK	OK	OK	
Sodium nitrate	7631-99-4	<45%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>45%	LIM	LIM	LIM	OK	OK	OK	OK	OK	OK	
Sodium perborate	10332-33-9	<3%	OK	OK	OK	---	---	OK	OK	OK	OK	
		>3%	NO	NO	NO	NO	---	OK	OK	OK	OK	
Sodium silicate (water glass)	1344-09-8	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	NO	NO	OK	---	OK	OK	OK	OK	OK	
Sodium sulfate	7757-82-6	<10%	---	---	OK	---	OK	OK	OK	OK	OK	
		>10%	---	---	LIM	---	OK	OK	OK	OK	OK	
Sodium tetraborate	1330-43-4	<10%	---	---	OK	---	OK	OK	OK	OK	OK	
		>10%	---	---	OK	---	OK	OK	OK	OK	OK	
Sodium thiosulfate	7772-98-7	<40%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>40%	NO	NO	OK	---	OK	OK	OK	OK	OK	
Stannous chloride	7772-99-8	<20%	---	---	LIM	---	OK	OK	OK	OK	OK	
		>20%	NO	NO	NO	NO	OK	LIM	OK	OK		
Sucrose pure	57-50-1		---	---	OK	---	OK	OK	OK	OK	OK	
Sulfur dioxide	7446-09-5		NO	NO	OK(T)	---	---	---	---	---	---	
Sulfur trioxide	7446-11-9		NO	NO	NO	NO	NO	NO	NO	NO	NO	
Sulfuric acid	7664-93-9	<50%	NO	NO	NO	NO	NO	OK	LIM	OK	OK	
		>50%	NO	NO	NO	NO	NO	NO	NO	NO	NO	
Sulfurous acid	7788-99-2	<50%	NO	NO	LIM	---	OK	OK	OK	OK	OK	
		>50%	NO	NO	LIM	---	OK	OK	NO	OK	NO	
Tartaric acid	87-69-4	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	
		>10%	LIM	LIM	LIM	LIM	LIM	OK	OK	OK	OK	
Tetrachloroethylene	127-18-4		NO	NO	NO	NO	NO	LIM	NO	OK	NO	
Tetrahydrofuran	109-99-9		NO	NO	NO	NO	NO	NO	NO	NO	NO	

MIXTRON DOSING UNIT

SEALS

LEGENDA:

OK	Compatible
OK(T)	Compatible (suction tube may have limited duration)
LIM	Limited compatibility (reduced duration)
NO	Non compatible
---	Data N/A

DISCLAIMER AND NOTES:

- 1) Data displayed are relative so compliance with one single chemical: compliance with mixtures of chemicals may be different
- 2) Data displayed are based in general on documentation, not always based on specific testing
- 3) When data are not available or in case of doubt, ask Mixtron for deeper analysis
- 4) Data displayed are recommendation only: in case of critical applications, User is responsible for testing in own operating conditions

ADDITIVE	CAS #	Conc. limits	MIXTRON DOSING UNIT						SEALS				
			P110	P022 P054 P150	P022 BYP P054 BYP P150 BYP	P003	P003 BYP	V	E	VX	EX		
Toluene	108-88-3		NO	NO	NO	NO	NO	NO	NO	NO	NO	NO	NO
Tributyl phosphate	126-73-8		---	---	OK(T)	---	OK(T)	NO	OK	NO	OK	NO	OK
Trichloroacetic acid	76-03-9	<50%	NO	NO	NO	---	OK	NO	LIM	NO	OK	NO	OK
		>50%	NO	NO	NO	---	OK(T)	NO	LIM	NO	OK	NO	OK
Trichloroethylene	79-01-6	<50%	---	LIM	LIM	LIM	LIM	LIM	LIM	LIM	NO	OK	NO
		>50%	NO	NO	NO	NO	NO	LIM	NO	OK	NO	NO	NO
Triethanolamine	102-71-6		OK(T)	LIM	LIM	NO	NO	NO	NO	NO	NO	NO	NO
Trisodium phosphate	7601-54-9	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Turpentine	9005-90-7		OK(T)	NO	NO	NO	NO	OK	NO	OK	NO	NO	NO
Urea	57-13-6	<10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
		>10%	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Water distilled	7732-18-5		OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Xylene	1330-20-7		LIM	NO	NO	NO	NO	LIM	NO	OK	NO	NO	NO
Zinc chloride	7646-85-7	<50%	LIM	LIM	OK	LIM	OK	OK	OK	OK	OK	OK	OK
		>50%	NO	NO	NO	---	OK	OK	OK	OK	OK	OK	OK
Zinc sulfate	1314-98-3	<10%	NO	NO	OK	LIM	OK	OK	OK	OK	OK	OK	OK
		>10%	NO	NO	OK	LIM	OK	OK	OK	OK	OK	OK	OK